

43

OFFICE OF THE CHIEF ELECTRICAL INSPECTOR

Office of the Chief Electrical Inspector Udyog Bhavan, 6th Floor, Block No.18, Sector-11, Gandhinagar.

No/CEI/Gan/Certi/28665/2020	E-mail : cel-epd@gujarat.gov.in	ph no : (079) 23256642 to 44
Date : 10/2/2020		fax no : (079) 232 566 51

To

GUJARAT ENERGY TRANSMISSION CORPORATION LTD [GETCO]**Gujarat Energy Trans Corp Ltd****Nadiad Dabhan Road****Nadiad****Gujarat Energy Trans Corp Ltd****Nadiad Dabhan Road****Nadiad****Vi.Dabhan****Ta.Nadiad****Dist.Kheda, 387320**

Subject Initial inspection for the electrical installation of 1 x 66 KV Feeder bay at 66kv Rozva along with associated equipments for 01 nos Feeder Bay for M/S J K Cement along with associated equipments at GUJARAT ENERGY TRANSMISSION CORPORATION LTD [GETCO], 66 kv Rozva ss, 66kv Rozva ss, Vi.Rozavada, Ta.Kapadvanj, Dist.Kheda, Gujarat, 387320.

Sir,

Initial Inspection of the Electrical Installation of 1 x 66 KV Feeder bay at 66kv Rozva along with associated equipments for 01 nos Feeder Bay for M/S J K Cement at 66 kv Rozva ss, 66kv Rozva ss, Vi.Rozavada, Kapadvanj, Kheda, Gujarat, 387320 for GUJARAT ENERGY TRANSMISSION CORPORATION LTD [GETCO] has been carried out by AEI, on 10/02/2020 and the same is found in order in accordance with the drawing approved vide this office letter No: No/CEI/Gan/Plan/28339/2020, Date: 03/02/2020. The details of the same are as following.

Details of Installation

Type of Line	No. of Feeder bay	Voltage Level in KV	Purpose	Location
Feeder bay	1	66 KV	01 nos Feeder Bay for M/S J K Cement	66kv Rozva

As provided under the Regulation of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulation, 2010 permission is hereby granted to energize the above installation along with the associated equipments.

Your's Faithfully

H H Khoja
CHIEF ELECTRICAL INSPECTOR
Gandhinagar

Copy forwarded to:

Applicant

73

OFFICE OF THE CHIEF ELECTRICAL INSPECTOR

Office of the Chief Electrical Inspector Udyog Bhavan, 6th Floor, Block No.18, Sector-11, Gandhinagar.

No/CEI/Gan/Cert/29825/2020

E-mail :
cel-epd@gujarat.gov.in

ph no : (079) 23256642 to 44

Date : 5/3/2020

fax no : (079) 232 566 51

To

GETCO

EE(TR)LIMBDI, DIVISION OFFICE, GETCO, 220KV S/S COMPOUND, LIMBDI
NEAR HONEST HOTEL, N.H NO.8, LIMBDI

Vi.Wadhwan

Ta.Wadhwan

Dist.Surendranagar, 363002

Subject Initial Inspection for the electrical installation of 1 x 10000.0 KVA 66/11 KV Transformer(s) & 1 x 2500.00 AMP 66.0 KV HT Breaker(s) along with associated equipments at GETCO, Village-Wadhwan, Vi.Wadhwan, Ta.Wadhwan, Dist.Surendranagar, Gujarat, 363002.

Sir,

Initial Inspection of the Electrical Installation of 1 x 10000.0 KVA 66/11 KV Transformer(s) & 1 x 2500.00 AMP 66.0 KV HT Breaker(s) at Village-Wadhwan, Vi.Wadhwan, Wadhwan, Surendranagar, Gujarat, 363002 for GETCO has been carried out by AEI, Surendranagar on 14/02/2020 and the same is found in order in accordance with the drawing approved vide this office letter No: No/CEI/Gan/Plan/25464/2019, Date: 18/11/2019. The details of the same are as following.

Details of Installation

Equipments	Make	Capacity	Sr. No.	Voltage level/Voltage ratio (KV)
Transformer	Voltamp	10000.0 KVA	JN 3271/2	66/11
HT Breaker	ABB	2500.00 AMP	70020772	66.0

As provided under the Regulation 43 of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulation, 2010 permission is hereby granted to energize the above installation along with the associated equipments.

Fire protection system shall be installed for power transformer as required under regulation 44 (2) (ix) of The Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010 within three months from the date of this permission.

Your's Faithfully

H H Khoja
CHIEF ELECTRICAL INSPECTOR
Gandhinagar

Copy forwarded to:



Office of the Dy. Chief Electrical Inspector Saurashtra Zone

3rd Floor, Block No. 1, Jilla Seva Sadan - T. Opp. Race Course, RAJKOT-360 001
Phone: 0283 - 2443075
E-mail: dycei-ced:raj@gujarat.gov.in

No. DCEIMWZ/INS/GETCO/800/887

3292

Date:

24 APR 2019

To,
Executive Engineer,
Transmission Division,
Gujarat Energy Transmission Corporation Limited,
220 KV Sub Station,
Varto, Bhavnagar

Subject: Initial Inspection of the Electrical Installation of 66 KV Bandar Road S/S with
1x15 MVA 66/11 KV Transformer along with associated equipments
At: Bhavnagar, Ta: Bhavnagar, Dist: Bhavnagar.
Ref 1: Plan Approval Letter No. CEIT-1/P-2/GETCOSS/0339/17/1034, Dt. 12-02-2018
Ref 2: Your Letter No. 18-19/VRJ/CEI/Augmentation-Tr.bay/2393, Dt. 28/09/2018:

Sir,

Initial inspection of the electrical installation of 66 KV Bandar Road S/S with 1x15 MVA
66/11 KV Transformer along with associated equipments At Bhavnagar, Ta Bhavnagar, Dist.
Bhavnagar has been carried out by the Jr AEI Bhavnagar on 27-11-2018 and Re-inspection on
05-03-2019. Details of the same are as below.

• Details of Installation:

Sr. No.	Particulars	Transformer-1
1	Make	Allanto
2	Capacity	15 MVA
3	Sr. No.	1009/4868
4	Volts	66/11 KV

As provided in the Regulation 43 of the Central Electricity Authority (Measures relating to
Safety and Electric Supply) Regulations, 2010, permission is hereby granted to energize the
above Electrical Installations subject to condition that regulation 44(2)(ix) & 44(2)(vii)(b) shall be
compiled with.

(M K Patel)

Dy. Chief Electrical Inspector
Saurashtra Zone, Rajkot

Copy respectfully submitted to:
The Chief Electrical Inspector, Gandhinagar... for kind information.

Copy to:
The Asst. Electrical Inspector, Bhavnagar... for information.

DE(r)
Ph give
copy to
VE. City 36

29/4

77

OFFICE OF THE CHIEF ELECTRICAL INSPECTOR

Office of the Chief Electrical Inspector Udyog Bhavan, 6th Floor, Block No.18, Sector-11, Gandhinagar.

No/CEI/Gan/Certi/30355/2020

E-mail :
cei-epd@gujarat.gov.in

ph no : (079) 23256642 to 44

fax no : (079) 232 566 51

Date : 16/3/2020

To

GETCO

Transmission Division Office, Near Nana Chiloda,

On N.H.No.8, Ranasan, Ahmedabad Post: Naroda-

Vi.Ahmadabad (Part)

Ta.Ahmedabad City

Dist.Ahmedabad, 382330

Subject Initial inspection for the electrical installation of 1 x 100000.0 KVA 132/66 KV Transformer(s) & 1 x 3150.00 AMP 132.0 KV HT Breaker(s) along with associated equipments at GETCO, Transmission Division Office, Near Nana Chiloda, , On N.H.No.8, Ranasan, Ahmedabad Post: Naroda-, Vi.Ahmadabad (Part), Ta.Ahmedabad City, Dist.Ahmedabad, Gujarat, 382330.

Sir,

Initial inspection of the Electrical Installation of 1 x 100000.0 KVA 132/66 KV Transformer(s) & 1 x 3150.00 AMP 132.0 KV HT Breaker(s) at Transmission Division Office, Near Nana Chiloda, , On N.H.No.8, Ranasan, Ahmedabad Post: Naroda-, Vi.Ahmadabad (Part), Ahmedabad City, Ahmedabad, Gujarat, 382330 for GETCO has been carried out by EI, Gandhinagar on 16/03/2020 and the same is found in order in accordance with the drawing approved vide this office letter No: No/CEI/Gan/Plan/25458/2019, Date: 18/11/2019. The details of the same are as following.

Details of Installation

Equipments	Make	Capacity	Sr. No.	Voltage level/Voltage ratio (KV)
Transformer	IMP	100000.0 KVA	PT-8229	132/66
HT Breaker	ABB	3150.00 AMP	19004627	132.0

As provided under the Regulation 43 of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulation, 2010 permission is hereby granted to energize the above installation along with the associated equipments.

Your's Faithfully

H H Khoja
CHIEF ELECTRICAL INSPECTOR
Gandhinagar

Copy forwarded to:

Applicant

Deputy Chief Electrical Inspector, Central Zone - Gandhinagar

Electrical Inspector, Ahmedabad

76

139

OFFICE OF THE CHIEF ELECTRICAL INSPECTOR

Office of the Chief Electrical Inspector Udyog Bhavan, 6th Floor, Block No.18, Sector-11, Gandhinagar.

No/CEI/Gan/Certi/28666/2020

E-mail :
cei-epd@gujarat.gov.in

ph no : (079) 23256642 to 44

Date : 10/2/2020

fax no : (079) 232 566 51

To
GUJARAT ENERGY TRANSMISSION CORPORATION LTD [GETCO]
Construction Division
GETCo
Vi.Dabhan
Ta.Nadiad
Dist.Kheda, 387320

Subject Initial inspection for the electrical installation of 66 KV S/C Dog Tower Line (5.78 KM) from 66kv Rozva Sub-Station to Ms. J K Cement, Vadadla along with associated equipments at GUJARAT ENERGY TRANSMISSION CORPORATION LTD [GETCO], 66kv Rozva s/s., GETCo, Vi.Vadadala, Ta.Balasinor, Dist.Mahisagara, Gujarat, 388255.

Sir,

Initial Inspection of the Electrical Installation of 66 KV S/C Dog Tower Line (5.78 KM) from 66kv Rozva Sub-Station to Ms. J K Cement, Vadadla at 66kv Rozva s/s., GETCo, Vi.Vadadala, Balasinor, Mahisagara, Gujarat, 388255 for GUJARAT ENERGY TRANSMISSION CORPORATION LTD [GETCO] has been carried out by AEI, on 10/02/2020 and the same is found in order in accordance with the drawing approved vide this office letter No: No/CEI/Gan/Plan/26809/2019, Date: 24/12/2019. The details of the same are as following.

Details of Installation

Type of Line	Length of Line(KM)	Type of Conductor	Total Location No.	From Location	To Location
Single circuit OH Line	5.78	Dog	28	66kv Rozva Sub-Station	Ms. J K Cement, Vadadla

As provided under the Regulation of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulation, 2010 permission is hereby granted to energize the above installation along with the associated equipments.

Your's Faithfully

H H Khoja
CHIEF ELECTRICAL INSPECTOR
Gandhinagar

Copy forwarded to:

Applicant
 Deputy Chief Electrical Inspector, Central Zone - Gandhinagar
 Electrical Inspector, Nadiad
 Assistant Electrical Inspector, Nadiad
 Executive Engineer (GETCO)

56.3

Signature y

Digitally signed by H H KHOJA
 HAIDERABAD HUSAINI
 Date: 2020.02.10 20:00
 Reason: Secure Docum